


SCALE: 1"=30'
ELECTRICAL SITE PLAN
SITE PLAN

KEYED NOTES

1. CONDUIT AND CONDUCTORS PER POWER COMPANY REQUIREMENTS. SEE CIVIL UTILITY DRAWINGS.
2. PROPOSED POWER COMPANY TRANSFORMER LOCATION.
3. SERVICE ENTRANCE CONDUIT AND CONDUCTOR SIZES IN ACCORDANCE WITH POWER COMPANY REQUIREMENTS. REFER TO CIVIL UTILITY PLANS FOR EXACT LOCATION OF UTILITY TRANSFORMER AND ROOMS OF CONDUITS.
4. TELEPHONE CABINET WITH LOCKING COVER PER UTILITY COMPANY REQUIREMENTS. VERIFY LOCATION PRIOR TO ROOFING.
5. 2" RIGGING TELEPHONE SERVICE ENTRANCE CONDUIT CONDUIT A MINIMUM OF 24" BELOW GRADE. VERIFY EXISTING TELEPHONE SERVICE ENTRANCE CONDUIT LOCATION.
6. CONDUIT AND CONDUCTORS FROM MAIN PANEL TO EXISTING PANEL. SEE ONELINE FOR SIZES.
7. EXISTING 400 AMP BUSB DISCONNECT TO REMAIN. ADDITIONAL INFORMATION.
8. SERVICE ENTRANCE SECTION. SEE ONELINE FOR ADDITIONAL INFORMATION.
9. EXISTING SERVICE FEEDER AND SNEED INTO NEW HILL INTO NEW FEEDERS AND PROVIDE ELECTRICAL CONNECTIONS AS REQUIRED.
10. J-BOX FOR ENTRY MOUNTMENT SON. COORDINATE EXACT LOCATION WITH CIVIL PLANS.
11. EXISTING CABLE TV. PERMITAL LOCATION.
12. 2" RIGGING CABLE TV. SERVICE ENTRANCE CONDUIT CONDUIT A MINIMUM OF 24" BELOW GRADE FOR ENTIRE LENGTH.
13. EXISTING TELEPHONE PERMITAL LOCATION.
14. CABLE TV. CABINET WITH LOCKING COVER PER CIVIL COMPANY REQUIREMENTS. VERIFY LOCATION PRIOR TO ROOFING.

Western Design Group, Inc.
2 West St. George Blvd.
Ancestor Square Suite 10
St. George, Utah 84770
435/656.1312 Fax 656.1355
westerndesign@qwest.net

CONSULTANTS
VAN BOERUM & FRANK ASSOCIATES INC.
1000 N. 1000 E. ST. GEORGE, UT 84770
435.542.2118 F
VBA Project Number: 818



PAINTER'S SERVICE CENTER
1600 HILTON DR.
ST. GEORGE, UTAH 84770

JIM PAINTER

MARK	DATE	DESCRIPTION
CD		
PP		
DD	//	

PROJECT NO.: VBFAS-8108
MODEL TITLE:
DRAWN BY: K. BEATTY
CHKD BY: L. REMBERG
COPYRIGHT:

SHEET TITLE
ELECTRICAL SITE PLAN

SHEET E1.0 OF